






Side View




Isometric View

p-h
graph.


ground floor - comm. supermarket



first floor - residential household (6 people)



second floor.



#	Variable	Why It Matters	Suggested Value / Range
1	Outdoor Dry Bulb Temperature	Primary basis for cooling/heating load calculations	40–45 °C (Delhi summer design)
2	Outdoor Relative Humidity	Determines latent heat load and dehumidification requirement	40–60% RH
3	Geographic Location / Climate Zone	Defines design conditions, solar intensity, seasonal variation	Composite Climate
4	Solar Radiation Intensity	Major contributor to heat gain through roof/walls/windows	700–950 W/m ²
5	Building Orientation (Sun Facing Direction)	East/west facades experience higher solar loads	Long axis: North–South preferred
6	Wind Speed & Direction	Affects infiltration, ventilation effectiveness, heat transfer	2–5 m/s prevailing winds
7	Adjacent Building Height & Spacing	Causes shading or heat trapping; impacts airflow	1–1.5× building height clearance
8	Wall Material & Thickness	Governs conductive heat transfer (U-value)	230 mm brick wall + plaster
9	Roof Construction & Insulation	Roof receives maximum solar load in India	RCC slab + 50 mm insulation
10	Window-to-Wall Ratio (WWR)	Larger glazing increases solar heat gain	25–40%
11	Glass Type / SHGC / U-Value	Impacts radiation and conductive heat entry	Double glazed, SHGC ≈ 0.3–0.4
12	Occupancy Density (People per Floor)	Humans contribute sensible + latent heat	GF: 15–25 people FF: 4–6 people SF: 2–5 staff
13	Equipment & Appliance Heat Load	Lighting, refrigerators, electronics, commercial machinery	GF: 20–40 W/m ² FF: 10–15 W/m ² SF: 50–120 W/m ²
14	Ventilation Requirement / ACH	Fresh air requirement directly impacts HVAC tonnage	GF: 6–10 ACH FF: 3–5 ACH SF: 10–20 ACH
15	Infiltration Rate	Leakage through doors/windows increases cooling load	0.3–0.7 ACH
16	Floor Usage Type	Commercial, residential, and cryogenic spaces have radically different HVAC demands	GF: Retail FF: Residential SF: Cryogenic/Industrial
17	Required Indoor Design Conditions	Desired temperature/humidity for each floor defines final system sizing	GF: 22–24 °C, 50% RH FF: 23–26 °C, 45–60% RH SF: –20 °C to –80 °C

Table 1.1: Suggested Values for Parameters




Chart 1 reveals the seasonal structure of the building load. The SF base load of 15,257 kWh per month is the flat constant floor under all twelve bars. The GF and FF contributions sit on top of it, peaking in June and July and nearly disappearing in December and January.

Chart 2 shows the monthly cash flow dip in May, June, and July when the GF and SF electricity bills peak simultaneously with Delhi summer. This is the stress period for the business - net monthly surplus drops from Rs 1.45 lakhs in winter to Rs 85,000 in peak summer.

The charts are a cause and consequence to one another, the bill shows rise during the middle of the year, and thus the net cash flow decreases during those parts of the year.






Chart 3 shows the P&L structure. The HVAC electricity cost of Rs 23.5 lakhs sits alongside a cost of goods figure of Rs 44.5 lakhs.


In the context of a Rs 63.5 lakh revenue business, HVAC is a significant but not dominant cost - comparable to what any capital-intensive food or pharmaceutical business spends on cold chain infrastructure.

— Saturation curve (100% RH) — RH curves (10-90%) — Enthalpy lines ● Your state point (45°C, 10%RH)



● O - outdoor (35°C, 21.4 g/kg) ● R - room (24°C, 9.3 g/kg) ● M - mixed air (26.2°C, 11.7 g/kg)
● CC - coil leaving (13°C, 8.4 g/kg) ● S - supply air (14°C, 8.4 g/kg) ● ADP - apparatus dew point





This is the line graph for different DBTs and WBTs (orange and blue lines) for different seasons (shown as background colour). The legend is as follows.

Summer (Mar-Jun)

Peak sensible load
DBT governs
Size condensers

Monsoon (Jul-Sep)

Peak latent load
WBT governs
Size dehumidification

Transition (Oct-Nov)

Part-load operation
Economiser mode
Free cooling potential

Winter (Dec-Feb)

Heating load (FF)
Heat pump mode
Humidification needed

2.2.5 Tabularised Parameters

Parameter	Value	Used for
Summer DB (0.4%)	43.9°C	Equipment sizing - critical spaces
Summer DB (1%)	42.2°C	Equipment sizing - comfort spaces
Coincident WB at summer DB	24°C	Psychrometric analysis, coil selection
Summer WB (0.4%)	28.3°C	Evaporative cooler feasibility, latent load
Monsoon coincident DB/WB	35°C / 28°C	Latent load, dehumidification coil sizing
Winter DB (99.6%)	4.5°C	Heating load, heat pump sizing
Winter DB (99%)	6.8°C	General heating load
Latitude	28.6°N	Solar angle calculations, SHGF table selection
Longitude	77.2°E	Solar time correction
Elevation	216 m	Atmospheric pressure correction (minor)
Prevailing wind speed (summer)	3-5 m/s from SW	Infiltration calculations